

West's Annotated Indiana Code [Currentness](#)

Title 22. Labor and Safety

▣ [Article 11. Building and Safety Regulations](#)

→ [Chapter 18. Smoke Detection Devices](#)

→ **22-11-18-1 Definitions**

Sec. 1. As used in this chapter:

“Bodily injury” has the meaning set forth in [IC 35-41-1-4](#).

“Dwelling” means a residence with at least one (1) dwelling unit as set forth in [IC 22-12-1-4\(a\)\(1\)\(B\)](#) and [IC 22-12-1-5\(a\)\(1\)](#).

“Hotels and motels” means buildings or structures kept, maintained, used, advertised, or held out to the public as inns or places where sleeping accommodations are furnished for hire for transient guests.

“Landlord” has the meaning set forth in [IC 32-31-3-3](#).

“Owner” means a person having control or custody of any building covered by this chapter.

“Person” means an individual, corporation, partnership, association, or other legal entity.

“Rental premises” has the meaning set forth in [IC 32-31-7-3](#).

“Rental unit” has the meaning set forth in [IC 32-31-3-8](#).

“Smoke detector” means a device which senses visible or invisible particles of combustion and conforms to the minimum standards for type, components, and maintenance prescribed by the National Fire Protection Association.

“Seasonally occupied dwellings” means hotels and motels open to the public for occupancy by guests only during any period of time between April 15 and October 15 each year.

“Single level dwellings” means all single level (no more than one (1) level above ground) hotels and motels

that have no interior corridors, and whose individual rooms have exterior exits.

“Tenant” has the meaning set forth in [IC 32-31-3-10](#).

### **22-11-18-2 Application of chapter; exemption**

Sec. 2. (a) This chapter applies to all hotels, motels, and dwellings.

(b) A totally sprinkled building (conforming to Uniform Building Code standards at the time of construction) is exempt from the requirements of this chapter.

### **22-11-18-3 Hotels and motels; installation of smoke detectors**

Sec. 3. (a) This section only applies to hotels and motels.

(b) All hotels and motels must have functional smoke detectors.

(c) Except as provided in subsection (f), a detector must be installed in all interior corridors adjacent to sleeping rooms and must be spaced no farther apart than thirty (30) feet on center, or more than fifteen (15) feet from any wall.

(d) The detectors must be hard wired into a building's electrical system, except as provided in subsection (f).

(e) The detectors must be wired in a manner that activates all the devices in a corridor when one (1) is activated, except as provided in subsection (f).

(f) All single level dwellings, all seasonably [\[FN1\]](#) occupied dwellings, and all hotels and motels with twelve (12) sleeping rooms or less (and containing no interior corridors) are exempt from the requirements of subsections (c), (d), and (e). In all such units:

(1) a detector must be installed in each sleeping room; and

(2) the detector may be battery operated.

If a battery operated detector is installed, it must contain a tamper resistant cover to protect the batteries. The fire marshal shall adopt rules detailing the specifications for the tamper resistant cover. If a battery operated

detector is not installed, the detector must be hard wired into a building's electrical system.

[FN1] So in 1983 enrolled act. Probably should read "seasonally".

### **22-11-18-3.5 Dwellings; installation of smoke detectors**

Sec. 3.5. (a) This section only applies to dwellings.

(b) A rule or an ordinance is not voided or limited by this section if the rule or ordinance:

(1) applies to an occupied dwelling; and

(2) is at least as stringent as the requirements of this section.

(c) A dwelling must have at least one (1) functional smoke detector installed as follows:

(1) According to the manufacturer's instructions.

(2) Outside of each sleeping area in the immediate vicinity of the bedrooms.

(3) On the ceiling or a wall not less than four (4) inches or more than twelve (12) inches from the ceiling. However, a smoke detector may not be recessed into a ceiling.

(4) On each additional story of the dwelling, including basements, cellars, and habitable attics. Unless there is a door between levels in dwellings with split levels, a smoke detector must be installed only on the upper level if the lower level is less than one (1) full story below the upper level.

(d) All smoke detectors must be:

(1) battery operated or hard wired into the dwelling's electrical system;

(2) accessible for servicing and testing; and

(3) maintained and at least one (1) time every six (6) months tested by the occupant to ensure that the smoke detector is in operational condition.

(e) Each owner or the manager or rental agent of the owner is responsible for:

(1) the installation of a required smoke detector; and

(2) the replacement and repair of a required smoke detector within seven (7) working days after the owner, manager, or rental agent is given written notification of the need to replace or repair the smoke detector.

(f) A person may not tamper with or remove a smoke detector except when necessary for maintenance purposes.

(g) A unit (as defined in [IC 36-1-2-23](#)) may adopt an ordinance concerning dwellings that:

(1) includes more stringent or detailed requirements than those set forth in this chapter; and

(2) does not conflict with this chapter.

#### **22-11-18-3.6 Violations; effect on claims**

Sec. 3.6. A violation of [section 3.5](#) of this chapter does not constitute grounds for a reduction or denial of a claim under an insurance policy even if the policy contains terms to the contrary.

#### **22-11-18-4 Compliance with other laws, ordinances, etc.**

Sec. 4. Compliance with this chapter does not relieve the owner from the requirements of any other applicable law, ordinance, rule, or regulation.

#### **22-11-18-5 Violations; offenses**

Sec. 5. (a) An owner of a hotel or motel who violates this chapter commits a Class A infraction, except as provided by subsection (b).

(b) An owner of a hotel or motel commits a Class D felony if:

(1) the owner knowingly or intentionally violates [section 3](#) of this chapter; and

(2) bodily injury or loss of life occurs as a result of a fire in the building.

(c) Except as provided in [section 5.5](#) of this chapter, a person who violates [section 3.5](#) of this chapter commits a Class D infraction.

#### **22-11-18-5.5 Violations by landlord**

Sec. 5.5. A landlord who violates [section 3.5](#) of this chapter:

(1) at the time the landlord delivers a rental unit to a tenant; or

(2) if the smoke detector is hard wired into the rental unit's electrical system, by failing to repair or replace the inoperable smoke detector not later than seven (7) days after receiving written notice by certified mail, return receipt requested, of the need to repair or replace the inoperable smoke detector under [section 3.5\(e\)\(2\)](#) of this chapter;

commits a Class B infraction. However, the offense is a Class A infraction if the landlord has a prior violation for an offense under this section.

#### **22-11-18-6 Inspections to determine compliance**

Sec. 6. (a) The state fire marshal's office shall, as part of its normal inspection process, conduct inspections of hotels and motels to determine if the detectors are installed and functioning in compliance with this chapter.

(b) Except for common areas shared by at least three (3) dwellings, a dwelling may not be inspected solely to determine compliance with [section 3.5](#) of this chapter unless the owner or occupant of the dwelling gives permission.

(c) Any evidence of a violation of this chapter shall be turned over to the prosecuting attorney of the county where the violation occurred.

END OF DOCUMENT